



# Oregon

Kate Brown, Governor

Early Learning Division  
Office of Child Care



451  
HEIDI HO PRESCHOOL AND KINDERGARTEN  
1110 SPRING ST  
LA GRANDE OR 97850

## RE: CC501226 Lead Testing Results Summary

The Facility must post the most recent lead test results summary provided by OCC in an area of the facility where the summary can be clearly viewed by parents. The facility must post the lead test results summary immediately after receiving the summary from OCC.

### Lead Test Results:

Name/Location	Pass/Fail	Mitigation Strategy	Approved	Retest Date
Basement fountain	Pass			8/8/2024
Basement south fountain	Pass			8/8/2024
Kitchen east	Pass			8/8/2024
Kitchen west	Pass			8/8/2024
main floor drinking fountain	Pass			8/8/2024
Playgroun drinking fountain	Pass			8/8/2024

If test results show that water from any drinking water faucet or fixture has 15 parts per billion (ppb) or more of lead, the facility must:

- Prevent access to that drinking water faucet or fixture immediately after receiving the test results; and
- Continue to prevent access to that drinking water faucet or fixture until mitigation is completed and approved by the Office of Child Care

CC: Heidi Mayberry, Licensing Specialist

File: